

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-09453
Name of Facility: David Fairchild Elem.
Address: 5757 SW 45 Street
City, Zip: South Miami 33155

**Correct By: Next Inspection
Re-Inspection Date: None**

Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Lucy Amengual Phone: 305-665-5483

Inspection Information

Purpose: Routine
Inspection Date: 9/9/2016

Begin Time: 09:15 AM
End Time: 10:45 AM

Additional Information

FEMALES CENSUS
MALES

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
X 5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	X 19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

General Comments

No General Comments Available

Email Address(es): lamengual@dadeschools.net

Inspector Signature:

Samartha Pley

Client Signature:

L Amengual

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

<p>Violation #5. Maintenance & Repair Clean excessive dust from the air ducts located in the Portable Classroom and throughout the entire main office area especially in the Clinic and Teacher Planning Room 019. Repair broken tiles along the floor and baseboard of the bathroom located in A-3. CODE REFERENCE: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.</p>
<p>Violation #19. Drinking Fountains Clean and remove excess build-up from the mouth of the water fountains located next to 013A Zone Mechanic closet, and Bathroom 013. Repair or increase pressure in water fountains located in classrooms C-7, C5, and B1 (Reading Lab). CODE REFERENCE; Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.</p>

Inspection Conducted By: Samantha Bley (32763)
Work: (305) 623-3500 ex.24322
Date: 9/9/2016

Inspector Signature:

Samantha Bley

Client Signature:

Admon...